

ADDRESS REPLY TO  
CHIEF OF ENGINEERS, U.S. ARMY  
WASHINGTON, D. C.

WAR DEPARTMENT  
OFFICE OF THE CHIEF OF ENGINEERS  
WASHINGTON

REFER TO FILE NO.

Room 251, Building 23  
General Electric Co.  
Schenectady, New York  
September 29, 1944

Barco Engineering Co.  
25 West Wacker Drive  
Chicago 6, Ill.

Almo, 32,000 KV. Generator  
Contract 49-013-eng-4

Gentlemen:

On inspection of the above, Hugday generator, shaft  
was made here today by the following representatives:

Mr. Louis Almo, representing Government of Uruguay  
Mr. Louis Almo, representing Barco Engineering Co.  
Mr. J. J. Holly, representing Int. Nat. B. E. Co.  
Mr. J. J. Henningsen, representing Gen. Elec. Co.  
Mr. J. J. Hoff, representing Construction Board  
Mr. J. J. Green, representing U. S. Engineers

The large hole in the lower side bearing journal  
where non-metallic inclusions were previously observed  
had been drilled, and the metal filled out between the  
drilled hole or each of the three areas.

I made a visual inspection of all three of the  
machined areas, no non-metallic inclusions could be seen,  
and only bare metal was observed.

Photographs and a print of sketch showing the  
machined areas are enclosed.

Yours very truly,

Mr. J. J. Giron  
Mr. J. J. Holly  
Mr. J. J. Henningsen  
Mr. J. J. Hoff

Inc. photo. and sketch under sep. cover

